



Prince George's County
Department of Environmental Resources
Permits and Review Division

Electrical Bulletin EC 2002-01

DATE: October 4, 2002

SUBJECT: Arch-fault Circuit-Interrupter
Protection

PURPOSE: To adopt the provisions related to
Article 210-12 of the 1999 National Electrical Code
(NEC), "arch-fault circuit-interrupter protection".

AUTHORITY: This Electrical Bulletin is issued by
authority granted to the Chief Electrical Inspector
as detailed in Subtitle 2, Division 14 B and
Subtitle 9 of the Prince George's County Code.

NOTIFICATION: All multi-family and residential
building permits issued after January 1, 2003,
shall be required to meet the provisions of Article
210-12 "arch-fault circuit-interrupter protection"
of the 1999 NEC.

Inquiries: Should you have questions regarding this
bulletin, please contact my office (301) 883-5780

Wayne H. Robinson
Chief Electrical Inspector
Engineering & Plans Review Section
Permits and Review Division
Effective date 1/1/03