

**Attachment for Fire Bulletin F02-01
Aboveground Storage Tanks**

Please attach this document with the plans when applying for permit.

Permit Applicant: _____

Installation Contractor: _____

Project Address: _____

Type of Tank: UL 142/2085 listed or other indicated below:

Purpose of the Tank: _____

Type of Fuel: _____

Please note Underwriters Listing must be provided to the field inspector.

The following conditions are applicable:

Aboveground Storage Tanks (AST):

- i) AST 660 gallons or less shall have a minimum listing of UL 142, double walled
- ii) AST exceeding 660 gallons up to 6,000 gallons shall have a minimum listing of UL 2085 or have an equivalent fire resistive rating of 2 hours.
- iii) AST exceeding 6,000 gallons in a common area shall obtain written permission from the Fire Chief or his authorized representative (DER/Fire Code Official).