



PRINCE GEORGE'S COUNTY
DEPARTMENT OF ENVIRONMENTAL RESOURCES
DEVELOPMENT SERVICES BRANCH
PERMITS AND REVIEW DIVISION

Stang
11/21/02

NOV 15

Fire Protection Bulletin

F02-01

DATE: November 18, 2002

- SUBJECT:** Outdoor Detached Aboveground Storage Tanks (AST) for Flammable and Combustible Liquids, Class I and II, (6,000 gallons or less).
- PURPOSE:** To provide resolution of Section 11-260 of the Fire Safety Law of Prince George's County for the design, plan review and installation of outdoor AST. The AST must also be detached from any/all structures. This bulletin is applicable to cumulative AST 6,000 gallons or less within the common area. Those AST or cumulative AST greater than 6,000 gallons must request written permission from the Fire Chief or his authorized representative (Department of Environmental Resources (DER)/Fire Code Official). This bulletin does not preclude any individuals from submitting and obtaining the proper permits and inspections.
- AUTHORITY:** This Fire Protection Bulletin is issued by authority granted to the Fire Code Official in Section 4-109 Duties and Powers of Building Official; Fire Safety Provisions of the Prince George's County Code. Orders of the State Fire Marshal are by authority of Article 38A, Section 8(a)(3), of the Annotated Code of Maryland.